



H-TAP PART NUMBER	H-TAP & CLEAR COVER KIT PART NUMBER	CONDUCTOR SIZES CODE WIRE (FLEX CABLE)						WIRE STRIP LENGTH	CRIMP DIE COLOR CODE	PANDUIT INSTALLATION TOOLS		
		MAIN	TAP 1	TAP 2	TAP 3	CT-930 CT-930CH CT-940CH* CT-2940*	CT-920 CT-920CH CT920			CT-2931		
		CRIMP DIE NO./DIE INDEX NO. (# OF CRIMPS=1)										
HTCT8-8-1	HTWC8-8-1	8-14 (8-14)	8-14 (8-14)	--	--	19/32"	GREEN	CD-920H-8 PH8	CD-920H-8 PH8	CD-920H-8 PH8		
HTCT6-6-1	HTWC6-6-1	6-10 (6-10)	6-14 (6-14)	--	--	11/16"	ORANGE	CD-920H-6 PH6	CD-920H-6 PH6	CD-920H-6 PH6		
HTCT2-2-1	HTWC2-2-1	2-6 STR/SOL (2-8)	2-6 STR/SOL (2-8)	8-14 (8-14)	8-14 (8-14)	13/16"	BROWN	CD-920H-2 PH2	CD-920H-2 PH2	CD-920H-2 PH2		
HTCT250-8-1	HTWC250-8-1	250-2 (4/0-2)	8-14 (8-14)	8-14 (8-14)	--	1"	PURPLE	CD-930H-250 PH25	-	CD-930H-250 PH25		
HTCT250-2-1	HTWC250-2-1	250-2 (4/0-2)	2-6 STR/SOL (2-8)	8-14 (8-14)	--	1"	PURPLE	CD-930H-250 PH25	-	CD-930H-250 PH25		
HTCT250-250-1	HTWC250-250-1	250-2 (4/0-2)	250-2 (4/0-2)	--	--	1"	PURPLE	CD-930H-250 PH25	-	CD-930H-250 PH25		

\*REQUIRES CD-940-DA ADAPTER

- NOTES:
1. MATERIAL: ANNEALED HIGH CONDUCTIVITY COPPER, TIN PLATED
  2. FOR USE WITH COPPER OR TIN PLATED COPPER CONDUCTORS ONLY.
  3. ACCOMODATES CODE CABLE, SOLID WIRE (WHERE SPECIFIED), FLEX LOCOMOTIVE (DLO), AND FLEX CLASSES G, H & I.
  4. ANY SINGLE TAP OR COMBINATION OF TAPS MAY BE USED IN CONJUNCTION WITH MAIN WIRE PORT.
  5. UL LISTED AND CSA CERTIFIED FOR APPLICATIONS UP TO 600V. TEMPERATURE RATING 90°C MAX.
  6. FLAME RETARDANT CABLE TIES (UL94 V-0 RATED NYLON WITH L.O.I.=28 MIN.) ARE PROVIDED WITH THE TAPS TO RETAIN THE WIRES IN POSITION FOR CRIMPING.
  7. TO ORDER H-TAP WITH INSULATING COVERS SEE PART NUMBERS IN TABLE.
  8. H-TAPS AND KITS ARE PACKAGED INDIVIDUALLY. (-1 PACKAGING CODE)



LISTED WIRE CONNECTOR



CERTIFIED

CAD FILENAME/LAYERS C41379\_02

PANDUIT CORP TINLEY PARK, ILLINOIS

H-TAP SERIES COPPER COMPRESSION SMALL TAPS

UNLESS OTHERWISE SPECIFIED, DIMENSIONAL TOLERANCES ARE:  
 (.X) ± .X (.XXX) ± .X  
 (.XX) ± .03 ANGLES ± .X

UNLESS OTHERWISE SPECIFIED, ALL DIMENSIONS ARE GIVEN IN INCHES, THIRD ANGLE PROJECTION

REV	DATE	BY	CHK	DESCRIPTION	ECN #	PM	CUST
02	11/04	RGB		ADDED CT-2931 COLUMN TO THE TABLE			
01	05/03	RWK	RLS	REMOVED BLACK COVER KIT NUMBERS	10818	LSM	JAC
00	04/03	RWK	RLS	DRAWING RELEASED	10794	LSM	JAC

DRAWN BY	DATE	SCALE	DWG
RWK	4/21/03	NONE	B
CHK'D			
RLS			

MAT'L: SEE NOTES

DRAWING NO. C41379